Boarding Home Interior Finishes Checklist/Guideline

Updated 08/11/09

Provided	Documents to be provided:	Regulation
	Application: Incomplete applications will prevent review of the submitted documents.	WAC 246-314-015(1)(a)
	Review Fee: $120 for projects only involving "Interior finishes" as defined in the WAC 246-314-010(3) as "…products such as carpet, vinyl wall covering, wall paper, or paneling applied to an existing surface as the exposed surface."	WAC 246-314-015(1)(c), WAC 246-314-990
	Functional Program: Renovation may create conditions that compromise the health and safety of residents, staff, and visitors. Facility planning must include provisions for infection control and safety of the facility's occupants during any renovation. Provide information on how the facility will: • Keep potential airborne contaminants generated by the work from reaching occupants of the facility; • Keep exit pathways open or redirected during the project; and • Keep the room or area unavailable for use until it is free of volatile fumes and odors.	WAC 388-78A-2850(3)
	Floor Plan(s) showing: • Facility layout with Project location identified • Rooms and areas defined by function and room names or numbers that are located in the project area; and • Locations of the proposed interior finish products.	WAC 388-78A-2820/2850
	Miscellaneous information: If the project involves carpet, then include a copy of the: • Manufacturer and style(s) • Radiant panel test report for each carpet style to be used in: - Corridor/exiting system: - Facility w/ a fire sprinkler system – "Pill Test", Class II, or Class I; and - Facility w/o a fire sprinkler system – Class II or Class I - All other areas of the facility: "Pill Test". Class II or Class I. • MSDS (Material Safety Data Sheet) for all products that contain chemicals that may be harmful such as glues, seam sealers, etc. If the project involves wall covering 1/28 inch (.90mm) thick or thicker , then include a copy of: • Manufacturer and style(s) • Flame and smoke rating: - Facility equipped with a fire sprinkler system – Class C - Facility without a fire sprinkler system: – Corridors/exiting system - Class B - All other areas – Class C	WAC 388-78A-2850(1)(b)(vi) WAC 388-78A-2850(1)(b)(vi)